



A specialist energy consultancy

# Environmental Noise Impact Assessment

## Rigifa Battery Energy Storage (BESS) Development

Field

16369-004-R0

24 September 2024

COMMERCIAL IN CONFIDENCE



[tneigroup.com](https://tneigroup.com)

## Quality Assurance

TNEI Services Ltd, TNEI Africa (PTY) Ltd and TNEI Ireland Ltd operate an Integrated Management System and is registered with The British Assessment Bureau as being compliant with ISO 9001 (Quality), ISO 14001 (Environmental) and ISO 45001 (Health and Safety).

## Disclaimer

This document is issued for the sole use of the Customer as detailed on the front page of this document to whom the document is addressed and who entered into a written agreement with TNEI. All other use of this document is strictly prohibited, and no other person or entity is permitted to use this report unless it has otherwise been agreed in writing by TNEI. This document must be read in its entirety and statements made within may be based on assumptions or the best information available at the time of producing the document and these may be subject to material change with either actual amounts differing substantially from those used in this document or other assumptions changing significantly. TNEI hereby expressly disclaims any and all liability for the consequences of any such changes. TNEI also accept no liability or responsibility for the consequences of this document being relied upon or being used for anything other than the specific purpose for which it is intended, or containing any error or omission which is due to an error or omission in data used in the document that has been provided by a third party.

This document is protected by copyright and may only be reproduced and circulated in accordance with the Document Classification and associated conditions stipulated or referred to in this document and/or in TNEI's written agreement with the Customer. No part of this document may be disclosed in any public offering memorandum, prospectus, or stock exchange listing, circular or announcement without the express and prior written consent of TNEI. A Document

Classification permitting the Customer to redistribute this document shall not thereby imply that TNEI has any liability to any recipient other than the Customer.

Any information provided by third parties that is included in this report has not been independently verified by TNEI and as such TNEI accept no responsibility for its accuracy and completeness. The Customer should take appropriate steps to verify this information before placing any reliance on it.

## Document Control

Revision	Status	Prepared by	Checked by	Approved by	Date
D0	DRAFT	EW	MC	MC	30/08/2024
R0	FIRST ISSUE	EW	MC	MC	24/09/2024

### TNEI Services Ltd

**Company Registration Number: 03891836**

**VAT Registration Number: 239 0146 20**

#### Registered Address

Bainbridge House  
86-90 London Road  
Manchester  
M1 2PW  
Tel: +44 (0)161 233 4800

7<sup>th</sup> Floor West One  
Forth Banks  
Newcastle upon Tyne  
NE1 3PA  
Tel: +44 (0)191 211 1400

7<sup>th</sup> Floor  
80 St. Vincent Street  
Glasgow  
G2 5UB  
Tel: +44 (0)141 428 3180

### TNEI Ireland Ltd

**Registered: 104 Lower Baggot Street, Dublin 2, D02 Y940**

**Company Registration Number: 662195**

**VAT Registration Number: 3662952IH**

Unit S12, Synergy Centre  
TU Dublin Tallaght Campus  
Tallaght  
D24 A386  
Tel: +353 (0)190 36445

### TNEI Africa (Pty) Ltd

**Registered: Mazars House, Rialto Rd, Grand Moorings Precinct, 7441 Century City, South Africa**

**Company Number: 2016/088929/07**

Unit 514 Tyger Lake  
Niagara Rd & Tyger Falls Blvd  
Bellville, Cape Town  
South Africa, 7530

### TNEI Inc.

**Registered Address: 9319 Robert D/ Snyder Rd. PORTAL Building Mecklenburg County  
Charlotte, NC 228223-0001 USA**

**Certification Number: C202305805696-1**

Unit 216 PORTAL Building,  
9319 Robert D. Snyder Road  
Charlotte, Mecklenburg County,  
North Carolina 28223  
Tel: +1 (980) 245-4024

# Contents

Document Control.....	3
Contents.....	4
1 Introduction .....	6
1.1 Nomenclature.....	6
2 Project Description.....	8
2.1 Study Area .....	8
3 Assessment Methodology.....	9
3.1 Legislation and Policy Context.....	9
3.1.1 PAN 1/2011 .....	9
3.2 Assessment Method .....	9
3.2.1 BS 4142:2014 +A1:2019 .....	9
3.3 EHO Consultation and Agreed Criteria .....	10
3.4 Calculation Method .....	11
3.4.1 Noise Propagation Model (ISO 9613-2) .....	11
3.4.2 Uncertainties and Limitations .....	11
4 Baseline Sound Level Monitoring .....	12
5 Operational Noise Impacts .....	14
5.1 Modelling of Individual Sound Sources .....	14
5.1.1 Battery Storage (DC) Unit Rows .....	14
5.1.2 MV Skid (AC) Units .....	15
5.1.3 High-Voltage Grid Transformer Units .....	15
5.2 Additional Mitigation Measures .....	16
5.3 Calculated Immission Levels.....	16
6 Noise Impact Assessment .....	18
6.1 BS 4142 Rating Level.....	18
6.1.2 Calculation of the Rating Level.....	19
6.1.3 Assessment of the Impacts .....	19
6.1.4 Consideration of 100 Hz frequency.....	20
7 Cumulative Impacts .....	21
7.1 Nearby Cumulative Developments.....	21
7.2 Cumulative Assessment.....	21
8 Summary .....	22
9 References .....	23



## TABLES

Table 4-1: Unattended Baseline Noise Monitoring Locations .....	12
Table 4-2: Representative Background Sound Level, dB $L_{A90}$ , Derived Through Statistical Analysis ....	13
Table 5-1: One-Third Octave Band SWL (dBA) values used to model the Battery Storage Unit Rows.	14
Table 5-2: One-Third Octave Band SWL (dBA) values used to model the MV Skid (AC) Unit (30% Load)	15
Table 5-3: One-Third Octave Band SWL (dBA) values used to model the HV Grid Transformers .....	16
Table 5-4: Noise Assessment Locations .....	16
Table 5-5: Predicted Immission Levels, dB $L_{Aeq(t)}$ .....	17
Table 6-1: BS4142 initial estimate for daytime and night-time .....	19
Table 7-1: Summary of Nearby Cumulative Developments.....	21

## FIGURES

Figure 6-1: NAN-R-45 Assessment Criterion Curve.....	20
--	----

## APPENDICES

Appendix A – Glossary of Terms
Appendix B – Development Information
Appendix C – EHO Consultation Data
Appendix D – Baseline Survey Data
Appendix E – Noise Modelling Data
Appendix F – Figures
Appendix G – One-Third Octave Band Predicted Levels (dBZ)
Appendix H – Cumulative Assessment Table

# 1 Introduction

TNEI was commissioned by Field (henceforth referred to as ‘the Client’) to undertake an environmental Noise Impact Assessment (NIA) in support of the Section 36 planning application for the proposed Rigifa Battery Energy Storage System (BESS) development (henceforth referred to as ‘the Proposed Development’).

The Proposed Development is located approximately 18 km east of the town of Thurso in the Scottish Highlands, at approximate Ordnance Survey coordinates 329441, 970987. The Proposed Development will have a storage capacity of 200 MW and will connect to the adjacent planned and consented 132 kV Gills Bay National Grid Substation. The Proposed Development site is currently undeveloped agricultural/pastural land.

The local area around the site is rural in nature, predominantly consisting of agricultural and pastoral land, but with a number of residential properties located nearby to the north and northeast.

The purpose of this NIA is to:

- Identify the noise sensitive receptors in the vicinity of the Proposed Development;
- Identify the dominant sound sources associated with the operation of the Proposed Development;
- Calculate the likely levels of operational noise at the identified receptors to determine the likely noise impacts associated with the Proposed Development; and,
- Indicate any requirements for mitigation measures, if applicable, to provide sufficient levels of protection for all noise sensitive receptors.

For clarity, this NIA considers the operational phase of the development only and does not include an assessment of construction noise. Typically, construction noise for this type of development is temporary in nature and usually dealt with at the post-consent phase via best practice mitigation measures during construction.

All work undertaken to produce this report has been carried out by members of the TNEI Environment and Engineering Team, all of whom are affiliated with the Institute of Acoustics (IOA). Specifically, the following members of staff have been involved in the project:

- Will Conway, Tech IOA, BSc (Hons): Baseline Sound Level Survey;
- Ewan Watson, AMIOA, BEng (Hons), IOA Postgraduate Diploma in Acoustics and Noise Control: Noise Propagation Modelling, Assessment and Reporting; and,
- Moise Coulon, Member IOA (MIOA), BSc Information Technology, IOA Postgraduate Diploma in Acoustics and Noise Control: Reporting and quality assurance.

## 1.1 Nomenclature

Please note the following terms and definitions, which are used throughout this report:

- **Emission** refers to the noise level emitted from a noise source, expressed as either a sound power level or a sound pressure level;
- **Immission** refers to the sound pressure level received at a specific location from a noise source;
- **SWL** indicates the sound power level in decibels (dB);
- **SPL** indicates the sound pressure level in decibels (dB);

- **NML** (Noise Monitoring Location) refers to any location where baseline noise levels have been measured;
- **NSRs** (Noise Sensitive Receptors) are all identified receptors that are sensitive to noise; and
- **NAL** (Noise Assessment Location) refers to any location where the noise immission levels are calculated and assessed.

A Glossary of Terms is also provided as Appendix A of this report.

All figures referenced within the report can be found in Appendix F.

Unless otherwise stated, all sound levels refer to free field levels i.e., sound levels without influence from any nearby reflective surfaces.

All grid coordinates refer to the Ordnance Survey grid using Eastings and Northings.

## 2 Project Description

The Proposed Development principally comprises a battery energy storage system (BESS) that will charge and discharge electricity from the adjacent proposed Gills Bay 132 kV National Grid Substation. It includes a single battery compound comprising battery storage units arranged into rows, medium-voltage (MV) skids (each skid comprising a MV transformer and two Power Conversion System (PCS) units) and associated ancillary equipment including low voltage (LV) cabinets and auxiliary transformers; a substation compound which accommodates high-voltage grid transformers, switchgear and a control building, as well as site-wide supporting infrastructure including an interface substation, underground cabling, access tracks, fencing and landscape and biodiversity mitigation and enhancement measures. Whilst the exact specifications of the Proposed Development are subject to detailed design, the principal components described form the basis of the planning application to allow environmental assessments and mitigation to be appropriately scoped.

Considering the above, the Proposed Development would introduce new sound sources to the local area. Specifically, the dominant sound sources considered within the assessment are:

- Battery Storage (DC) Unit Rows (400 of);
- MV Skid (AC) Units (50 of); and
- High-Voltage Grid Transformer Units (2 of).

The layout assessed here is for a BESS with a storage capacity up to 200 MW, as included in Appendix B.

The sound level output of the ancillary infrastructure (e.g. interface substation, switchgear, control building, auxiliary transformers etc.) of the Proposed Development is considered insignificant in comparison to the primary sound sources detailed above. Accordingly, no other items of plant have been considered within the assessment.

### 2.1 Study Area

Noise Sensitive Receptors (NSRs) are properties that are sensitive to noise and, therefore, require protection from nearby noise sources. The study area for the assessment of environmental noise is usually defined through the identification of the closest NSRs to the development.

The assessment of noise attributable to the Proposed Development considers the nearest NSRs only, on the assumption that if sound levels at the closest receptors are deemed acceptable, then sound levels at NSRs at greater distances from the Proposed Development should also be within acceptable levels.

The nearest identified NSRs, which have a high level of sensitivity, are existing residential properties located to the north and northeast of the Proposed Development. The curtilage of the closest residential receptor is approximately 900 m to the northeast of the nearest noise emitting plant. Other residences are located approximately between 1,200 m and 1,800 m away.

Figure 1 within Appendix F details the study area and the closest NSRs considered within the assessment.

## 3 Assessment Methodology

### 3.1 Legislation and Policy Context

#### 3.1.1 PAN 1/2011

At a national level, the relevant policy is PAN 1/2011 (PAN) *Planning and Noise* <sup>(1)</sup> and the associated Technical Advice Note (TAN) *Assessment of Noise* <sup>(2)</sup>. With regards to the assessment of environmental noise, Appendix 1 of the TAN describes a number of standards and guidelines that may be referred to and details British Standard (BS) 4142 as appropriate for use.

### 3.2 Assessment Method

#### 3.2.1 BS 4142:2014 +A1:2019

BS 4142:2014 '*Methods for Rating and Assessing Industrial and Commercial Sound*' <sup>(3)</sup> is commonly used to assess the potential impacts of new sound sources on nearby receptors. The BS 4142 form of assessment is based on the predicted or measured levels of an assessed sound source compared to the measured background sound levels without the specific sound source present and uses, '*outdoor sound levels to assess the likely effects of sound on people who might be inside or outside a dwelling or premises used for residential purposes upon which sound is incident*'.

Specifically, the assessment is made by subtracting the measured background sound level from a calculated or measured 'Rating Level'.

BS 4142 uses the following definitions:

**Ambient Sound:** Totally encompassing sound in a given situation at a given time, usually composed of sound from many sources, both near and far. Described using the metric,  $L_{Aeq}(t)$ .

**Specific Sound Level:** Equivalent continuous A-weighted sound pressure level produced by the specific sound source at the assessment location over a given reference time interval,  $T_r$ . Described using the metric  $L_{Aeq}(t)$ . Also referred to in this report as the *Immission Level*.

**Residual Sound Level:** Equivalent continuous A-weighted sound pressure level of the residual sound without the specific sound source(s) present at the assessment location over a given time interval,  $T$ . Described using the metric  $L_{Aeq}(t)$ .

**Background Sound Level:** A-weighted sound pressure level that is exceeded by the residual sound at the assessment location for 90% of a given time interval,  $T$ , measured using time weighting  $F$  and quoted to the nearest whole number of decibels. Described using the metric  $L_{A90}(t)$ .

**Rating Level:** The Specific Sound Level adjusted for the characteristics of the sound. The Rating Level is calculated by adding a penalty or penalties (if required) to the Specific Sound Level when the sound source contains audible characteristics such as tonal, impulsive or intermittent components. Described using the metric,  $L_{Aeq}(t)$ .

Supplementary information regarding the application of BS 4142 is provided within the Association of Noise Consultants' (ANC) BS 4142 Technical Note (March 2020) <sup>(4)</sup>. The technical note provides guidance on the appropriate interpretation and application of the standard, including clarifying the methodology for the derivation of representative background sound levels.

The BS4142 standard require two key steps, at first an initial estimate (i.e. comparison of Rating Levels with Background Sound Levels) is undertaken and secondly an assessment of the context is required to conclude on potential noise impacts.

To inform some element of the context assessment, the technical note states the following with regards to the application of the standard in the event measured background sound levels and predicted Rating Levels are low:

*'... the absolute level of sound can be of significance, where the residual values are low and where they are high, and should be taken into account when determining the overall impact of a particular specific sound source. The second paragraph [of BS 4142] notes that absolute levels may be as, or more, important than relative outcomes where background and rating levels are low. It is important to note that both background and rating levels would need to be low for this particular caveat to apply. BS 4142 does not indicate how the initial estimate of impact should be adjusted when background and rating levels are low, only that the absolute levels may be more important than the difference between the two values. It is likely that where the background and rating levels are low, the absolute levels might suggest a more acceptable outcome than would otherwise be suggested by the difference between the values. For example, a situation might be considered acceptable where a rating level of 30dB is 10dB above a background sound level of 20dB, i.e. an initial estimate of a significant adverse impact is modified by the low rating and background sound levels.'*

With regards to what constitutes 'low', the technical note goes on to state:

*'BS 4142 does not define 'low' in the context of background sound levels nor rating levels. The note to the Scope of the 1997 version of BS 4142 defined very low background sound levels as being less than about 30 dB LA90, and low rating levels as being less than about 35 dB LAR,Tr. The WG suggest that similar values would not be unreasonable in the context of BS 4142, but that the assessor should make a judgement and justify it where appropriate.'*

Extracts underlined by TNEI for emphasis.

The additional information provided within the ANC technical note has informed TNEI's approach to the NIA assessment criteria with regards to the application of BS 4142. This is discussed further in Section 3.3.

### 3.3 EHO Consultation and Agreed Criteria

To agree a set of operational noise assessment criteria, TNEI undertook extensive consultation with an Environmental Health Officer (EHO) from The Highland Council (THC). All formal EHO consultation correspondence has been included within Appendix C of this report.

Initially, TNEI issued a letter to THC dated 8<sup>th</sup> February 2024 (document reference 16369-002-R0) to provide detail of the assessment and proposed noise monitoring locations for the baseline sound level survey. THC responded via email and agreed with the assessment approach and proposed monitoring locations, but also commented that background levels observed within the area would likely be very low (i.e. below 30 dBA) and that a main concern particular to the area is that of creeping background sound levels.

After having undertaken the baseline sound level survey (detail of which is included in Section 4 of this report), TNEI wrote to THC once again (document reference 16369-003-R1, dated 2<sup>nd</sup> August 2024) to discuss the baseline data and the potential for cumulative considerations to be included within the assessment. Primarily, TNEI explained within the letter that the prevailing background sound levels measured were not as low as expected and, through reference to existing baseline sound level survey data collected in the area as part of noise impact assessments for neighbouring energy developments, reasoned that the levels measured by TNEI were actually quite typical and reflective of the soundscape. Ultimately, the letter summarised the revised approach to the assessment as follows:

- The representative background sound level for all NSRs in the area is 35 dB LA90 (15 minutes) for both the daytime and night-time periods;

- An assessment will be undertaken in accordance with BS 4142, with a target for the Proposed Development's Rating Level to not exceed the representative background sound level at all NSRs;
- An assessment of the predicted noise level in the 100 Hz one-third octave frequency band will be undertaken to assess frequency content at the request of the EHO, and;
- A cumulative noise assessment will be presented, considering the nearby developments of Mey BESS, Gills Bay National Grid Substation and Hollandmey Renewable Energy Development.

The EHO confirmed (via email on 9<sup>th</sup> August 2024) that the above approach is deemed acceptable.

### 3.4 Calculation Method

#### 3.4.1 Noise Propagation Model (ISO 9613-2)

In order to predict the noise immission levels attributable to the Proposed Development, a noise propagation model was created using the propriety noise modelling software, CadnaA<sup>(5)</sup>. Within the software, complex models can be produced to simulate the propagation of noise according to a range of international calculation standards.

For this assessment noise propagation was calculated in accordance with ISO 9613 '*Acoustics – Attenuation of sound during propagation outdoors*'<sup>(6)</sup> using the following input parameters:

- Temperature is assumed to be 10 °C and relative humidity as 70%;
- A ground attenuation factor of 1 (soft ground) has been used except for the developed ground of the Proposed Development area and the adjacent consented Gills Bay Substation area, which has been modelled with a ground attenuation factor of 0 (hard ground); and
- Receiver heights have been set to 4 m.

#### 3.4.2 Uncertainties and Limitations

The noise propagation model is designed to give a good approximation of the specific sound level and the contribution of each individual sound source; however, it is expected that measured levels are unlikely to be matched exactly with modelled values. As such, the following limitations in the model should be considered:

- In accordance with ISO 9613, all assessment locations are modelled as downwind of all sound sources and propagation calculations are based on a moderate ground-based temperature inversion, such as commonly occurs at night. These conditions are favourable to noise propagation;
- The predicted barrier attenuation provided by local topography, embankments, walls, buildings and other structures in the intervening ground between source and receiver can only be approximated and not all barrier attenuation will have been accounted for;
- The model assumes all sound sources are operating continuously and simultaneously; and,
- Modelled sound sources represent candidate plant only and a proposed site layout. The noise output of individual items of plant may vary from what is presented in this report after final plant specification.



## 4 Baseline Sound Level Monitoring

To inform the BS 4142 assessment, an unattended baseline sound level survey was undertaken at two Noise Monitoring Locations (NMLs) over a 12-day period between the 8<sup>th</sup> and 20<sup>th</sup> of February 2024. The noise monitoring equipment logged in 15-minute averaging intervals and measured continually for the entire survey period at NML02, but for only 7 days at NML01, stopping unexpectedly on the 15<sup>th</sup> February due to battery failure.

Table 4-1 details the unattended NMLs which are shown on Figure 1 in Appendix F. The NMLs were selected to be representative of the NSRs in the vicinity of the Proposed Development.

**Table 4-1: Unattended Baseline Noise Monitoring Locations**

NML		Coordinates		Comments
NML01	Located within the field to the north of Phillips Mains	329842	972029	Was installed to be representative of the nearest NSRs located to the north of the Proposed Development
NML02	Located within the field to the southwest of Rigifa	330348	972559	Was installed to be representative of the nearest NSRs located to the northeast of the Proposed Development

All measurements were made with the sound level meters (SLMs) mounted approximately 1.2 m above the ground and away from nearby reflective surfaces i.e. building façades, fences etc. as practically possible.

The noise monitoring equipment consisted of two Cirrus Optimus Green SLMs fitted with appropriate environmental wind shields. All noise monitoring equipment (calibrator, SLM and microphones) used for the study is categorised as Class 1, as specified in IEC 61672-1 *'Electroacoustics. Sound level meters. Specifications'* <sup>(7)</sup>. The equipment was calibrated onsite at the beginning and end of the measurement period with no significant deviations noted. Appendix D contains the equipment and laboratory calibration details for the SLMs and Calibrator.

Subjective observations made during the installation and collection of the survey equipment noted the following:

- At NML01, the soundscape consisted of wind induced foliage rustle, watercourse noise from nearby drainage ditch, resident's dogs barking and occasional bird calls. The watercourse noise was constant.
- At NML02, the soundscape was dominated by wind-induced vegetation and foliage rustle. There were no other significant sources of noise identified at this location.

Meteorological data was collected onsite with a Kestrel portable weather station and a tipping bucket rain gauge, which were installed alongside the SLMs. All sound level data recorded during (as well as 20 minutes before and 60 minutes after) a recorded precipitation event was removed to reduce the potential influence of raised sound levels from rainfall. The data was also filtered for periods when wind speeds were above 5 m/s, to remove any data when noise levels could be atypically increased due to wind induced noise. In addition to this, data measured between the 8<sup>th</sup> and 11<sup>th</sup> of February



was manually excluded from the dataset due to atypically high measured  $L_{Aeq}$  values, which likely indicated that a noise source was present that was not representative of the typical background sound level. This manually excluded period is represented by the red crosses seen on the time-history graphs presented within Appendix D.

The representative background sound level for each NML was determined with reference to the time-history charts, statistical analysis charts and distribution analysis charts included in Appendix D, following the guidance in presented within the ANC technical note and BS 4142, which states:

*'A representative level should account for the range of background sound levels and should not automatically be assumed to be either the minimum or modal value.'*

With due consideration of the above, Table 4-2 details the representative background sound levels  $L_{A90 (15mins)}$  at each of the NMLs for the daytime and night-time periods.

**Table 4-2: Representative Background Sound Level, dB  $L_{A90}$ , Derived Through Statistical Analysis**

Noise Monitoring Location	Daytime $L_{A90 (15-mins)}$	Night-time $L_{A90 (15-mins)}$
NML01	48	48
NML02	35	35

Subjective observations on site noted that the soundscape at NML01 was influenced by water flowing from a nearby drainage ditch. The influence of the watercourse is clearly visible in the time-history graph included within Appendix D. It was therefore agreed with the EHO that the data measured at NML02 was representative of the soundscape surrounding the Proposed Development in the absence of watercourse noise.

At NML02, the measured background sound levels were somewhat higher than originally anticipated by the EHO, given the rural nature of the surrounding environment. However, having analysed the measured data at this location, there was no evidence to suggest that the data is invalid for use. In order to validate the use of this representative background sound level within the assessment, TNEI reviewed similar baseline datasets presented within the noise impact assessments for some nearby energy developments. It was found that 35 dB  $L_{A90}$  is a typical representative level for both daytime and night-time periods in the surrounding area and this was agreed with the EHO during consultation. As such, 35 dB  $L_{A90}$  is considered an appropriate representative background sound level value for all NSRs during both the daytime and night-time periods.

## 5 Operational Noise Impacts

### 5.1 Modelling of Individual Sound Sources

The noise model considers all of the sound sources detailed within Section 2 of the report. The following section describes how each sound source has been incorporated into the noise model. All items of plant have been modelled as area sources i.e. each side and top of each unit are modelled as individual sound sources and are assumed to be operating concurrently, continually and with a constant sound level output.

Noise modelling is based on candidate plant typical for the size and class of the Proposed Development. It should be noted that final plant specifications may vary during the tendering process. Where possible, noise modelling data is shown within Appendix E, however, where data cannot be published due to confidentiality reasons, TNEI would be happy to discuss this data in more detail with the Local Authority, if required.



#### 5.1.1 Battery Storage (DC) Unit Rows




Table 5-1: One-Third Octave Band SWL (dBA) values used to model the Battery Storage Unit Rows

Frequency (Hz)						
	50	63	80	100	125	160
	■	■	■	■	■	■
	200	250	315	400	500	630
	■	■	■	■	■	■
	800	1000	1250	1600	2000	2500
	■	■	■	■	■	■
	3150	4000	5000	6300	8000	10000
	■	■	■	■	■	■

### 5.1.2 MV Skid (AC) Units






























Table 5-2: One-Third Octave Band SWL (dBA) values used to model the MV Skid (AC) Unit (30% Load)

Frequency (Hz)						
	50	63	80	100	125	160
						
	200	250	315	400	500	630
						
	800	1000	1250	1600	2000	2500
						
	3150	4000	5000	6300	8000	10000
						

### 5.1.3 High-Voltage Grid Transformer Units

Two High Voltage (HV) grid transformers have been included within the noise model. In the absence of provided data from the Client, TNEI have used in-house One-Third Octave Band SWL data for a representative ABB candidate within the noise model. The data for the unit, which has an overall SWL of 88 dBA, is included within Appendix E and is shown below in Table 5-3:

**Table 5-3: One-Third Octave Band SWL (dBA) values used to model the HV Grid Transformers**

Frequency (Hz)						
HV Grid Transformer ABB Candidate	50	63	80	100	125	160
	64	48	55	72	69	78
	200	250	315	400	500	630
	74	77	80	77	77	79
	800	1000	1250	1600	2000	2500
	79	77	75	72	70	69
	3150	4000	5000	6300	8000	10000
	68	67	65	62	60	58

## 5.2 Additional Mitigation Measures

No specific noise mitigation measures (i.e. implementation of acoustic barriers or bunds) have been incorporated within the model. The only measures applicable are those embedded within the layout design due to other constraints outside of noise.

## 5.3 Calculated Immission Levels

Noise immission levels have been calculated at five Noise Assessment Locations (NALs), which have been selected to represent the closest NSRs to the Proposed Development. Each NAL has been set on the side of the property facing the Proposed Development, with the exception of NALs 02 and 03, which represent the front and rear amenity areas of Philips Mains respectively as both face the Proposed Development. The NALs are detailed in Table 5-4 and on Figure 2 in Appendix F:

**Table 5-4: Noise Assessment Locations**

Noise Assessment Location		OS Grid Reference	
NAL ID	NAL Descriptor	Eastings	Northings
NAL01	Phillips Mains A	329823	971979
NAL02	Phillips Mains B	329847	971952
NAL03	West Lodge	328916	972267
NAL04	East Lodge	330067	972714
NAL05	Rigifa	330428	972642

The immission levels (Specific Sound Level) were calculated assuming all plant is operating continuously and concurrently. The model assumes, as a worst case, that noise levels do not fluctuate

and remain the same for both daytime and night-time periods. The noise immission levels at the NALs are detailed in Table 5-5 below. The immission levels are also illustrated as a noise contour plot shown in Figure 2 of Appendix F.

**Table 5-5: Predicted Immission Levels, dB  $L_{Aeq(t)}$**

Noise Assessment Location		Immission Level, dB $L_{Aeq(t)}$
NAL ID	NAL Descriptor	
NAL01	Phillips Mains A	20
NAL02	Phillips Mains B	18
NAL03	West Lodge	21
NAL04	East Lodge	18
NAL05	Rigifa	15

## 6 Noise Impact Assessment

### 6.1 BS 4142 Rating Level

To assess the immission levels against the agreed criteria, the Specific Sound Level must be converted into a Rating Level. The Rating Level allows for character corrections to be added to account for particular characteristics of the sound that may be perceived as more annoying. In particular, the Rating Level considers tonality, impulsivity and intermittency of the sound, as well other sound characteristics that are neither tonal, impulsive, or intermittent, but are otherwise readily distinctive against the residual acoustic environment.

#### 6.1.1.1 Tonality

With regards to tonality, BS 4142 states:

*‘For sound ranging from not tonal to prominently tonal the Joint Nordic Method gives a correction of between 0 dB and +6 dB for tonality. Subjectively, this can be converted to a penalty of 2 dB for a tone which is just perceptible at the noise receptor, 4 dB where it is clearly perceptible and 6 dB where it is highly perceptible.’*

Electrical plant, such as power transformers, are often tonal at source, typically in the 100 Hz frequency band. BS 4142 corrections, however, are only applied if the noise characteristics are present at the receptor location, not at the source location.

Consideration of the predicted one-third octave band levels at the identified receptors against the assessment criteria presented in BS 4142’s informative ‘One-Third Octave Band Objective Method of Assessment’ indicates that no tonality is likely to be present. Details of the informative tonal analysis is presented in Appendix G. As such, given the results of the informative analysis and TNEI’s experience of noise assessments for BESS sites, no tonal character correction has been applied.

#### 6.1.1.2 Impulsivity

With regards to impulsivity, BS 4142 states:

*‘A correction of up to +9dB can be applied for sound that is highly impulsive, considering both the rapidity of the change in sound level and the overall change in sound level. Subjectively this can be converted to a penalty of 3dB for impulsivity which is just perceptible at the noise receptor, 6dB where it is clearly perceptible, and 9dB where it is highly perceptible.’*

Impulsivity is not considered to be a relevant sound characteristic of a BESS as when operational, the noise level will be predictable and consistent.

#### 6.1.1.3 Intermittency

The intermittency of the sound source needs to be considered when it has identifiable on/off conditions with regards to intermittency, BS 4142 states:

*‘If the intermittency is readily distinctive against the residual acoustic environment, a penalty of 3 dB can be applied.’*

As with impulsivity, intermittency is not considered to be a relevant sound characteristic in this case. Once operational, noise levels may fluctuate by a small amount over long periods of time, but no step changes in noise level are anticipated.

#### 6.1.1.4 Other Sound Characteristics

With regards to other sound characteristics, BS 4142 states:

*‘Where the specific sound features characteristics that are neither tonal nor impulsive, nor intermittent, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3 dB can be applied.’*

Based on TNEI’s understanding and experience of this type of plant, we do not anticipate any additional sound characteristics that would be considered readily distinctive against the residual acoustic environment.

#### 6.1.2 Calculation of the Rating Level

With due regard to the above, no character corrections are required. Therefore, the BS 4142 Rating Levels are equal to the Specific Sound Levels.

#### 6.1.3 Assessment of the Impacts

Table 6-1 presents the initial estimate of BS 4142, a comparison of the Rating Levels to against the representative background sound, which in this case are applicable to both daytime and night-time periods:

**Table 6-1: BS4142 initial estimate for daytime and night-time**

Noise Assessment Location		Rating Level, dBA	Representative Background Sound Level (Daytime and Night-time), dBA	Margin Above/Below (+/-) Fixed Rating Level Limit, dB
NAL ID	NAL Descriptor			
NAL01	Phillips Mains A	20	35	-15
NAL02	Phillips Mains B	18	35	-17
NAL03	West Lodge	21	35	-14
NAL04	East Lodge	18	35	-17
NAL05	Rigifa	15	35	-20

As shown in Table 6-1, the Rating Levels are considerably below the representative background sound level at all NALs during both the daytime and night-time period, which is *‘an indication of the specific sound source having a low impact, depending on the context’* according to the initial estimate of BS 4142.

The context in which the assessment is made is as follows:

- The assessment considers candidate plant and the typical sound level output for this type of plant. As part of the procurement process, plant will be specified in order to minimise noise output.
- The noise model assumes all plant is operating concurrently, however not all cooling units will necessarily be required to operate at the same time and as such, overall noise levels are likely to be lower than predicted.

It is considered that the context does not change the initial estimate outcome and as such the full BS 4142 assessment indicates that the specific sound source will have a low impact, when considering the context.

#### 6.1.4 Consideration of 100 Hz frequency


With due regard to the EHO concern regarding the noise level specifically at a frequency of 100 Hz, it is helpful to look at the absolute level of the noise predicted within this frequency band, (as opposed to relying solely on an assessment of tonality), and the DEFRA approved study by Salford University; 'NAN-R-45 Procedure for the assessment of low frequency noise complaints'<sup>(8)</sup> is helpful in this regard.

NAN-R-45 presents guidance with the aim of developing a method for the assessment of low frequency noise for use by Environmental Health practitioners in the UK. It provides a criterion curve to aid such an assessment, suggesting that if any particular frequency exceeds the curve this may indicate a source of low frequency noise that could cause disturbance.

The dB levels that define the curve are for noise levels measured inside a dwelling. This is reproduced as Figure 6-1 below.

**Figure 6-1: NAN-R-45 Assessment Criterion Curve**

Hz	10	12.5	16	20	25	31.5	40	50	63	80	100	125	160
dB, Leq	92	87	83	74	64	56	49	43	42	40	38	36	34



At 100 Hz, the internal NAN-R-45 criterion curve level is 38 dBZ. Appendix G presents the external calculated one third octave band noise levels at the closest NAL to provide an indicative comparison. The maximum external predicted noise level attributable to the Proposed Development within the 100 Hz band has been calculated as 26 dBZ, which is considerably below the internal NAN-R-45 criteria of 38 dBZ. Given the internal 100 Hz level is likely to be even lower than the predicted external level, it is considered highly unlikely that noise levels from the Proposed Development within the 100 Hz frequency band will cause any disturbance to residents.



## 7 Cumulative Impacts

### 7.1 Nearby Cumulative Developments

As discussed within the EHO letter included within Appendix C of this NIA report (document reference 16369-003-R1), there are a number of consented and proposed developments located near to the Proposed Development that require cumulative consideration in terms of operational noise output. The nearby cumulative developments considered are summarised within Table 7-1 below:

**Table 7-1: Summary of Nearby Cumulative Developments**

Development Name	Planning Reference	Planning Status	Approximate Site Centre OS Coordinates		Approximate bearing and distance from Proposed Development centre point	Approximate bearing and distance from nearest NALs
			Eastings	Northings		
Mey BESS	ECU00004838	Decision Pending	329634	972319	1300 m to the north	350 m to the north west of NAL01
Gills Bay National Grid Substation	21/05536/FUL	Consented	329215	971984	1000 m to the north	430 m to the southeast of NAL04
Hollandmey Renewable Energy Development	ECU00003353	Consented	329020	969944	1100 m to the south	2100 m to the southwest of NAL02

### 7.2 Cumulative Assessment

With regards to the above, a cumulative assessment was undertaken against the representative background sound levels presented within this NIA for both the daytime and night-time periods. Table H-1 within Appendix H of this NIA report shows the results of the cumulative assessment, in which the Proposed Development's Rating Levels have been logarithmically added together with the Rating Levels presented for the surrounding schemes.

As can be seen from Table H-1, the maximum cumulative Rating Level may be up to +5 dB above the daytime and night-time representative background sound level of 35 dB, in regard to BS 4142 initial estimate this would be an indication of a low impact depending on the context. Furthermore, the Rating Level from the Proposed Development on its own are very low at all NALs and are at least 10 dB below the cumulative predictions of the other schemes which means there are no differences in cumulative predictions with or without the Proposed Development. This is demonstrated within Table H-1.

As such, it is anticipated that the Rating Levels from the Proposed Development will not materially contribute to the cumulative noise levels.

## 8 Summary

To predict the noise immission levels of the Proposed Development, TNEI has produced a noise propagation model in accordance with ISO 9613 based on candidate plant typical for this type of development. The noise model assumes that all plant will be operating continuously and concurrently, however, this is unlikely to occur for the majority of the time. Accordingly, the noise assessment is inherently conservative. The noise model does not include any additional mitigation measures in the form of acoustic barriers or bunds.

The background levels were measured at 2 locations and results were presented and agreed with the Environmental Health Officer (EHO) at the Highland Council, along with an outline methodology and criteria which was also agreed.

The assessment shows that the Proposed Development's Rating Levels are very low at nearby receptors (below 20 dB) and the full BS 4142 assessment indicates that the specific sound source will have a low impact, when considering the context.

Operational noise from the Proposed Development is also not expected to have any tonal characteristics present in any frequency band (100 Hz or otherwise) when incident at the receptors. Additionally, the Rating Levels from the Proposed Development are so low that they are expected to be at least 10 dB below the cumulative noise levels of 3 other nearby proposed schemes in the surrounding area and will not materially contribute to the cumulative noise levels.

**As such, the Proposed Development is expected to have a low noise impact on the local area and no specific noise mitigation measures are anticipated to be required.**

Should the Scottish Ministers be minded to grant consent, TNEI would welcome continued consultation with THC and the Energy Consents Unit to help draft an appropriate set of planning conditions relating to operational noise, prior to a decision notice being issued.

## Appendix A – Glossary of Terms

---

**Attenuation:** the reduction in level of a sound between the source and a receiver due to any combination of effects including: distance, atmospheric absorption, acoustic screening, the presence of a building façade, etc.

**Background Sound Level:** the sound level rarely fallen below in any given location over any given time period, often classed according to daytime, evening or night-time periods. The LA90 indices (see below) are typically used to represent the background sound level.

**Broadband Noise:** noise with components over a wide range of frequencies.

**Decibel (dB):** the ratio between the quietest audible sound and the loudest tolerable sound is a million to one in terms of the change in sound pressure. A logarithmic scale is used in sound level measurements because of this wide range. The scale used is the decibel (dB) scale which extends from 0 to 140 decibels (dB) corresponding to the intensity of the sound level.

**dB(A):** the ear has the ability to recognise a particular sound depending on its pitch or frequency. Microphones cannot differentiate sound in the same way as the ear, and to counter this weakness the sound measuring instrument applies a correction to correspond more closely to the frequency response of the human ear. The correction factor is called 'A Weighting' and the resulting measurements are written as dB(A). The dB(A) weighting is internationally accepted and has been found to correspond well with people's subjective reaction to sound levels and noise. Some typical subjective changes in sound levels are:

- a change of 3dB(A) is just perceptible;
- a change of 5dB(A) is clearly perceptible; and
- a change of 10dB(A) is twice (or half) as loud.

**Directivity:** the property of a sound source that causes more sound to be radiated in one direction than another.

**Emission:** the sound energy emitted by a sound source (e.g. a wind turbine).

**Frequency:** the pitch of a sound in Hz or kHz. See Hertz.

**Ground Effects:** the modification of sound at a receiver location due to the interaction of the sound waves with the ground along its propagation path from source to receiver. Described using the term 'G', and ranges between 0 (hard ground), 0.5 (mixed ground) and 1 (soft ground).

**Hertz (Hz):** sound frequency refers to how quickly the air vibrates, or how close the sound waves are to each other (in cycles per second, or Hertz (Hz)).

**Immission:** the sound pressure level detected at a given location (e.g. the nearest dwelling).

**Noise:** unwanted sound.

**L<sub>w</sub>:** is the sound power level. It is a measure of the total sound energy radiated by a sound source and is used to calculate sound levels at a distant location. The LWA is the A-weighted sound power level.

**L<sub>eq</sub>:** is the equivalent continuous sound level, and is the sound level of a steady sound with the same energy as a fluctuating sound over the same period. It is possible to consider this level as the ambient noise encompassing all noise at a given time. The L<sub>Aeq, T</sub> is the A-weighted equivalent continuous sound level over a given time period (T).

**L<sub>90</sub>:** index represents the sound level exceeded for 90 percent of the measurement period and is used to indicate quieter times during the measurement period. It is often used to measure the background sound level. The L<sub>A90,10min</sub> is the A-weighted background sound level over a ten-minute measurement sample.




**Sound Level Meter:** an instrument for measuring sound pressure level.

**Sound Pressure Level:** a measure of the sound pressure at a point, in decibels.

**Tonal Noise:** noise which covers a very restricted range of frequencies (e.g. a range of  $\leq 20$  Hz). This noise is subjectively more annoying than broadband noise.

## Appendix B – Development Information

---



- Drawing Notes:**
1. All dimensions are shown in metres unless noted otherwise.
  2. Do not scale from this drawing.
  3. Planning boundary area = 45.381ha
  4. Landlord's property is unregistered and the area shown is the area within the landlord's property where construction work will be carried out. Refer to drawing number BTGBRIG01-008.1 for the landownership plan.

List of Addresses	
1	2 Phillips Mains, Mey, Thurso, KW14 8XH
2	West Lodge, Mey, Thurso, KW14 8XH
3	Woodlands, Mey, Thurso, KW14 8XH
4	Bruach House, Mey, Thurso, KW 14 8XH

**Legend**

Planning Boundary


5	12.09.2024	PLANNING BOUNDARY AREA AMENDED	JH	AP
4	19.04.2024	LANDLORD'S PROPERTY REMOVED 1:5000 SCALE ADDED TO SCALE BAR	JH	AP
3	18.04.2024	LANDLORD'S PROPERTY AND PLANNING BOUNDARY AMENDED	JH	JM
2	04.04.2024	LANDLORD'S PROPERTY AMENDED	JH	RS
1	25.01.2024	DETAILS ADDED TO SITE LOCATION PLAN	JH	AP
0	18.01.2024	SITE LOCATION PLAN - ORIGINAL	WL	JH
REV	DATE	DESCRIPTION	BY	CHKD




Field  
Fora - Montacute Yards  
186 Shoreditch High Street  
London  
E1 6HU

PROJECT		RIGIFA		
TITLE		SITE LOCATION PLAN		
DISCIPLINE		PLANNING		
DRAWING STATUS		FOR PLANNING		
SCALE	DATE	DRAWN BY	CHECKED BY	APPROVED BY
1:5000 @A1	25.01.2024	JH	JH	AP
PROJECT NO.	DRAWING NO.	REV.		
BTGBRIG01	002.1	5		





1 Detailed Site Layout Plan  
Scale 1:1000 (B/A)



2 Site Location Plan  
Scale 1:2500 (B/A)

- Drawing Notes:**
- All dimensions are shown in metres unless noted otherwise.
  - Do not scale from this drawing.

- Legend**
- Exclusivity Area
  - Interface Substation Exclusivity Area
  - Illustrative Access Route
  - Illustrative Cable Route
  - New SSE Substation Compound
  - SSE Proposed Cable Route
  - Temporary Construction Compound
  - Temporary Construction Working Area
  - Temporary Laydown Area
  - Access Road
  - Fencing
  - Attenuation Basin
  - Planting/Landscaping
  - Indicative 1.5m High Bund (Landscaping)

1:10	0	100mm	200mm	300mm	400mm	500mm	600mm	700mm	800mm	900mm	1m
1:20	0.5m	1m	1.5m	2m	2.5m	3m	3.5m	4m	4.5m	5m	5.5m
1:25	0.5m	1m	1.5m	2m	2.5m	3m	3.5m	4m	4.5m	5m	5.5m
1:50	1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m
1:100	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m
1:200	5m	10m	15m	20m	25m	30m	35m	40m	45m	50m	55m
1:250	5m	10m	15m	20m	25m	30m	35m	40m	45m	50m	55m
1:500	10m	20m	30m	40m	50m	60m	70m	80m	90m	100m	110m
1:1000	10m	20m	30m	40m	50m	60m	70m	80m	90m	100m	110m
1:2000	10m	20m	30m	40m	50m	60m	70m	80m	90m	100m	110m
1:5000	50m	100m	150m	200m	250m	300m	350m	400m	450m	500m	550m
1:5000	100m	200m	300m	400m	500m	600m	700m	800m	900m	1000m	1100m

5	12.09.2024	BESS compound amended and parking/landscaping area increased.	JH	JP
4	22.07.2024	Interface substation position amended.	JH	JP
3	12.07.2024	Site layout amended with reduced number of BESS blocks.	JH	JP
2	10.04.2024	Site layout amended.	JH	JM
1	04.04.2024	Construction compound amended and temporary construction working area added.	JH	RS
0	13.03.2024	Detailed Site Layout Plan - Original	JH	JM
REV	DATE	DESCRIPTION	BY	CHKD



Field  
Fora - Montacute Yards  
186 Shoreditch High Street  
London  
E1 6HU

PROJECT  
RIGIFA

TITLE  
Detailed Site Layout Plan  
Envision Twinskid  
200MW/1200MWh

DISCIPLINE  
DESIGN

DRAWING STATUS  
FOR INFORMATION

SCALE	DATE	DRAWN BY	CHECKED BY	APPROVED BY
As Shown	13.03.2024	JH	JM	RS
PROJECT NO.	DRAWING NO.	REV.		
BTGBRIG01	005.1	05		



## Appendix C – EHO Consultation Data

---



## Rigifa Battery Energy Storage System: Noise Impact Assessment

To: [REDACTED]

Planning Authority: The Highland Council

Address: By Email


TNEI Ref.: 16369-001-R0

Date: 8 February, 2024

Dear [REDACTED]

TNEI Services Ltd (TNEI) have been commissioned by Field Energy to undertake a Noise Impact Assessment to support the planning application for a Battery Energy Storage System (BESS) located in Rigifa, Caithness, at approximate coordinates, 329496, 970942. Image 1 details the approximate location.

**Image 1: Approximate site location**



The proposed development will introduce new sound sources into the area in the form of externally located battery banks, inverters and transformers.

Figure 1 (appended) details an indicative red line boundary and the nearest identified Noise Sensitive Receptors (NSRs), which are residential properties to the northeast and northwest of the Proposed Development.

### Proposed Assessment Method

TNEI propose to undertake an assessment in line with BS 4142:2014+A1-2019 Methods for Rating and Assessing Industrial and Commercial Sound (BS 4142), however, we recognise there are a number of alternative methods of assessment available, such as the use of fixed guideline levels e.g. BS 8233:2014, Noise Rating (NR) curves and other criteria specific to The Highland Council. Accordingly, if you would like us to consider any alternative approaches, then please advise and we would be happy to incorporate this into our assessment.

### Proposed Baseline Survey

In order to inform the BS 4142 assessment, TNEI are currently in the process of undertaking a baseline sound level survey at three locations. These are shown on the appended Figure 1, the NMLs have been coloured to match the NSRs that they will represent e.g. the data measured at the yellow NML will be used to represent all of the NSRs marked as yellow.

Continuous unattended monitoring will be undertaken for a period of at least 7 days and the noise levels will be logged in 15-minute intervals. A rain gauge and a small wind speed monitor have also been installed at one of the NMLs. All periods measured during periods of precipitation will be removed from the dataset. Similarly, all data will be removed during periods of high windspeeds.

Following the conclusion of the survey, a representative background sound level will be determined for each NML following the guidance presented in both BS 4142 and the Association of Noise Consultants' (ANC) BS 4142 Technical Note, March 2020. The assessment will predict operational noise levels from the Proposed Development at the nearest identified NSRs, on the assumption that if noise is within acceptable levels at these locations, it will also be acceptable at more distant locations. We will aim to conclude on potential impact and mitigation requirements at the closest NSRs identified.

If background sound levels are very low, the initial estimate of BS 4142 (comparing rating levels against the background sound level) may not be an appropriate assessment methodology. Where background sound levels are determined to be very low i.e. below 30 dB  $L_{A90(t)}$ , and predicted Rating Levels are also likely to be low (less than 35 dB  $L_{Aeq(t)}$ ) then, as detailed within the ANC Technical Note, it may be more appropriate to undertake the assessment against an absolute noise level limit. Should this be the case, we will write to you beforehand to confirm these details.

### Summary

We hope the above provides you with a clear explanation as to the approach that we intend to adopt for this assessment. We would be very grateful if you could confirm your acceptance of this approach, or otherwise. If there is any aspect of the proposed survey or assessment method you would like to discuss in more detail, or if you would like further information with regards to the nature of the development, then please do not hesitate to get in touch.

Yours sincerely,



Ewan Watson

Senior Consultant

TNEI Services Ltd

## Document Control

Revision	Status	Prepared by	Checked by	Approved by	Date
R0	FIRST ISSUE	WC	EW	MC	08/02/2024

### TNEI Services Ltd

Company Registration Number: 03891836

VAT Registration Number: 239 0146 20

Registered Address

Bainbridge House

86-90 London Road

Manchester

M1 2PW

Tel: +44 (0)161 233 4800

7<sup>th</sup> Floor West One

Forth Banks

Newcastle upon Tyne

NE1 3PA

Tel: +44 (0)191 211 1400

7<sup>th</sup> Floor

80 St. Vincent Street

Glasgow

G2 5UB

Tel: +44 (0)141 428 3180

### TNEI Ireland Ltd

Registered Address: 104 Lower Baggot Street, Dublin 2, DO2 Y940

Company Registration Number: 662195

VAT Registration Number: 3662952IH

Unit S12, Synergy Centre

TU Dublin Tallaght Campus

Tallaght

D24 A386

Tel: +353 (0)190 36445

### TNEI Africa (Pty) Ltd

Registered: Mazars House, Rialto Rd, Grand Moorings Precinct, 7441 Century City, South Africa

Company Number: 2016/088929/07

Unit 514 Tyger Lake

Niagara Road & Tyger Falls Blvd

Belville


Cape Town 7530

South Africa,

Tel: +27 (0)72 855 6999




Appended: Figure 1 – NIA Study Area





## Rigifa Battery Energy Storage System (BESS) Development: Noise Impact Assessment – Further Correspondence

To:		Planning Authority:	The Highland Council
	The Highland Council,		
	Community Services,		
Address:	38 Harbour Road,	TNEI Document Ref.:	16369-003-R1
	Inverness, IV1 1UF		
Date:	2 August, 2024		

Dear 

As you are aware, TNEI Services Ltd (TNEI) have been commissioned by Field to carry out a Noise Impact Assessment (NIA) to support the Section 36 planning application for a proposed Rigifa Battery Energy Storage System (BESS) development (the Proposed Development) located approximately 22 km to the east of the town of Thurso, Highlands. The proposed site location and the nearest identified residential Noise Sensitive Receptors (NSRs) are shown in Figure 1 overleaf.

TNEI sent a letter to The Highland Council (THC) (Document Reference 16369-002-R0) on the 8<sup>th</sup> of February 2024, detailing our proposed methodology and baseline noise survey locations and to invite feedback on our proposed assessment methodology. We received a prompt response from yourself on 13<sup>th</sup> February 2024, confirming your acceptance of TNEI's proposed methodology and highlighting concern regarding the likelihood of low background sound levels in the area, inviting further discussion regarding the assessment upon completion of the baseline survey.

The noise impact assessment is now in a position to progress (with a target planning submission date of September 2024) and our baseline survey is now complete. As such, the purpose of this letter is to discuss the results of the baseline survey, the potential need for cumulative considerations, and to agree upon an appropriate methodology that will help us deliver a robust NIA report in line with THC's requirements.

### **Baseline Sound Level Survey**

The baseline survey was undertaken from the 8<sup>th</sup> to the 20<sup>th</sup> of February 2024. Monitoring was undertaken continually at two Noise Monitoring Locations (NMLs) and logged in 15-minute periods. The



derived representative background sound levels, which have been chosen by TNEI with reference to the appended statistical and distribution analysis graphs, are detailed in Table 1 below:

**Table 1 – TNEI’s Chosen Representative Background Sound Levels, dB LA90(15 minutes)**

Noise Monitoring Location (NML)	Daytime LA90	Night-time LA90
NML01	48	48
NML02	35	35

The NMLs are detailed within Figure 1 below:

**Figure 1 – Nearest Noise Sensitive Receptors (NSRs) and Noise Monitoring Locations (NMLs)**



At both NMLs, a measurement period of around 2 days has been excluded from the beginning of the datasets due to an undefined and atypical increase in noise levels. This can be seen in the time history plots as ‘manual exclusions’ and are represented as red crosses.

At NML01, subjective observations made during collection of the equipment noted that the soundscape was influenced by water flowing from a nearby drainage ditch. The influence of this can clearly be seen on the appended time-history graph, where background sound levels remain high (between approx. 45 and 50 dBA) throughout the survey, even at night. As such, we have decided that the data measured at this location is not appropriate for use to inform the assessment. It should also be noted for completeness that data was obtained at this location for a shorter duration due a battery failure after approximately 7 days (as seen in the NML01 time-history graph).

At NML02, background sound levels are somewhat higher than was originally anticipated, given the rural nature of the surrounding environment, however, there is nothing immediately obvious within the dataset to suggest that the data is invalid for use. Table 2 presents the calculated levels:

**Table 2: Background Sound Levels at NML02, dB LA90 (15 minutes)**

NML	Time Period	Mean	Median	TNEI Representative Level
NML02	Day	35	35	35
	Night	37	37	35

To seek validation of this background sound level, TNEI have reviewed similar baseline datasets presented within the noise impact assessments for some other nearby schemes.

**Mey BESS (ECU00004838):** Monitoring was undertaken at Philips Main, which is the nearest NSR to the Rigifa BESS development. The representative background sound levels at this location were reported as 35 dB LA90 (t)\* during the daytime and 34 dB LA90 (t)\* at night, which is very similar to the levels measured by TNEI.

\*Logging periods were not disclosed within the NIA report

**Gills Bay Substation (21/05536/FUL):** Long-term monitoring was also undertaken at Philips Main, as well as at two additional locations (West Lodge and Woodlands) located approximately 950 m west/northwest of Philips Mains. With regards to measured levels, the NIA report states:

*'The noise impact assessment provided in this report is an update to a previous noise impact assessment, following on from comments received from THC. The previous impact assessment used background noise data collected over one clear night on the night of 18/19 April 2016, with the lowest measured value of 28.2 dBA used in the subsequent assessment. The analysis of long-term noise data collected from 10 to 23 February 2016 has indicated that the majority of background noise levels at Phillips Main and West Lodge/Woodlands occur in the 30 - 40 dBA range.'*

Again, this dataset indicates similar background sound levels to the TNEI dataset.

Consideration of both TNEI's measured data (discussed above and appended) and the review of data contained within the NIA's for the neighbouring schemes gives confidence that a value of **35 dB LA90 (15 minutes)** is representative of the surrounding area's soundscape during the daytime and night-time, and appropriate for use within our assessment for all nearby NSRs.

### **Assessment Criteria**

TNEI understand, from extensive experience of consulting with THC's Environmental Health Officers, that the standard set of assessment criteria required by THC for BESS developments is as follows:

1. 'Noise arising from the development when measured and/or calculated as an L<sub>Zeq</sub> (5-minutes), in the 100 Hz one third octave frequency band must not exceed 30 dB, at noise sensitive premises; and
2. The Rating Level of noise arising from the use of plant, machinery, or equipment as a result of the development must not exceed the current background noise levels at noise sensitive premises. The Rating Level should be calculated in accordance with BS 4142: 2014+A1:2019: Methods for rating and assessing industrial and commercial sound.'

With regards to the 100 Hz limit of 30 dB L<sub>Zeq</sub> (5-minutes), TNEI have recently discussed this in depth with [REDACTED] (EHO at THC) also on behalf of Field regarding another of their BESS developments just outside of Inverness (Knocknagael).

TNEI understand that the limit has been imposed in the past by THC due to concerns regarding tonality within the 100 Hz band for electrical plant, most specifically for substations, however, we discussed how 30 dBZ is an extremely low level (approximately 11 dBA) and presented evidence as to why this could be unduly restrictive and not appropriate for a BESS development. Therefore, to demonstrate that tonality (at 100 Hz) would not be problematic, Robin agreed an alternative approach to the assessment and TNEI demonstrated that no tonal characteristics were expected in the immission levels in the 100 Hz One-Third Octave frequency band. This was achieved through a combination of the BS 4142 ‘One-Third Octave Band Objective Method of Assessment’ and comparison of the predicted levels against; ‘NAN-R-45 Procedure for the assessment of low frequency noise complaints’ (DEFRA), which presents guidance with the aim of developing a method for the assessment of low frequency noise for use by Environmental Health practitioners in the UK.

TNEI propose to adopt the same approach to the consideration of operational noise levels within the 100 Hz frequency band for the Proposed Development. If required, we can provide copies of the correspondence with Robin Fraser regarding the 100 Hz assessment approach at Knocknagael.

With regards to a Rating Level limit of 0 dB above background, TNEI are happy to comply with this request, which effectively sets a Rating Level limit of 35 dB  $L_{Aeq(t)}$  at all nearby residential receptors.

**Cumulative Considerations**

As discussed above, there are a number of proposed renewable energy/BESS schemes in the area surrounding the Proposed Development, and these may require cumulative consideration within our assessment. Table 3 summarises the developments that we intend to include within our assessment.

**Table 3: Proposed Neighbouring Schemes to be Considered within NIA**

Neighbouring Scheme	Planning Reference Number
Mey BESS	ECU00004838
Gills Bay Substation	21/05536/FUL
Hollandmey Renewable Energy Development	ECU00003353

Cumulative noise levels will be calculated at each receptor using the predicted noise levels presented in the NIA reports submitted for the May BESS and Gills Bay Substation.

For the Hollandmey Renewable Energy Development (which consists of a wind farm, as well as substation, BESS and solar farm), the NIA does not include a BS 4142 assessment, background sound levels or predicted noise levels from the substation, BESS or solar farm. However, the assessment states; “It is therefore proposed that combined noise levels from electrical plant at this facility should be limited to a rated noise level of no more than 30 dB  $L_{Aeq}$  at the nearest residential property.” As such, we will assume that the BS 4142 Rating Levels from this development are 30 dB  $L_{Aeq(t)}$  at all of the nearest receptors.

Our cumulative assessment will consider the likely cumulative noise levels from the operation of all of the above developments and seek to demonstrate that the cumulative noise level will either not exceed the background sound level i.e. 35 dBA, or that the site-specific noise levels from the Proposed Development will be at least 10 dB below the cumulative noise level of the neighbouring developments. For clarity, whilst we do agree that a cumulative noise assessment is necessary, TNEI do not believe that a cumulative noise condition is appropriate and would expect that any noise limits that are imposed would be site specific only.



We hope the above provides you with requisite additional information to allow us to agree upon an appropriate assessment methodology and progress with the assessment. To summarise;

- We have determined that the representative background sound level for all NSRs in the area is 35 dB L<sub>A90</sub> (15 minutes) for both the daytime and night-time periods;
- The site will be designed to ensure the Rating Level does not exceed the background sound level at all NSRs;
- An assessment of the predicted noise level in the 100 Hz one-third octave frequency band will be undertaken to ensure no tonality is present;
- A cumulative noise assessment will be presented, considering each of the developments as detailed within Table 3; and,
- The site will be assessed to ensure the cumulative level does not exceed the background sound level or, where this already occurs due to the existing cumulative levels from the neighbouring schemes, the site-specific noise level will be at least 10 dB below the existing cumulative noise level.

We would welcome any feedback you may have on the above, particularly with regards to the cumulative approach. If you feel that a call would be beneficial to discuss matters further, please do not hesitate to get in touch and we can look to arrange this.

[Redacted signature block]

## Document Control

Revision	Status	Prepared by	Checked by	Approved by	Date
R0	FIRST ISSUE	EW	JS	JS	31/07/2024
R1	CLIENT COMMENTS	EW	JS	JS	02/08/2024

### **TNEI Services Ltd**

**Company Registration Number: 03891836  
0146 20**

**VAT Registration Number: 239**

#### **Registered Address**

Bainbridge House  
86-90 London Road  
Manchester  
M1 2PW  
Tel: +44 (0)161 233 4800

7<sup>th</sup> Floor West One  
Forth Banks  
Newcastle upon Tyne  
NE1 3PA  
Tel: +44 (0)191 211 1400

6<sup>th</sup> and 7<sup>th</sup> Floor  
80 St. Vincent Street  
Glasgow  
G2 5UB  
Tel: +44 (0)141 428 3180

### **TNEI Ireland Ltd**

**Registered Address: 104 Lower Baggot Street, Dublin 2, DO2 Y940**

**Company Registration Number: 662195  
3662952IH**

**VAT Registration Number:**

Unit S12, Synergy Centre  
TU Dublin Tallaght Campus  
Tallaght  
D24 A386  
Tel: +353 (0)190 36445


### **TNEI Africa (Pty) Ltd**

**Registered: Mazars House, Rialto Rd, Grand Moorings Precinct, 7441 Century City, South Africa**


**Company Number: 2016/088929/07**

Unit 514 Tyger Lake  
Niagara Road & Tyger Falls  
Blvd  
Belville  
Cape Town 7530  
South Africa,  
Tel: +27 (0)72 855 6999

## 16369 - Rigifa BESS - Measured Sound Levels:




## 16369 - Rigifa BESS - Measured Sound Levels:




16369 - Rigifa BESS - Measured Sound Levels:

Statistical Analysis - NML01




Statistical Analysis - NML01




16369 - Rigifa BESS - Measured Sound Levels:

Statistical Analysis - NML02



Statistical Analysis - NML02



## 16369 - Rigifa BESS - Measured Sound Levels:

### Relevant Statistics

#### NML01

		COUNT	MEAN	MEDIAN	RANGE
DAYTIME	LA90 (15 MINS)	209	48	49	44 - 52
	LAEQ (15 MINS)	209	50	50	45 - 63
NIGHT-TIME	LA90 (15 MINS)	130	48	49	43 - 51
	LAEQ (15 MINS)	130	50	50	45 - 52

#### NML02

		COUNT	MEAN	MEDIAN	RANGE
DAYTIME	LA90 (15 MINS)	439	35	35	20 - 52
	LAEQ (15 MINS)	439	41	42	21 - 64
NIGHT-TIME	LA90 (15 MINS)	271	37	37	20 - 53
	LAEQ (15 MINS)	271	41	41	22 - 59



## Ewan Watson

---

**From:** Ewan Watson  
**Sent:** 09 August 2024 08:59  
**To:** [REDACTED]  
**Cc:** [REDACTED]  
**Subject:** Re: Rigifa BESS Development - Noise Impact Assessment

Good Morning [REDACTED]

Thank you very much for your response.

Thanks for confirming - we will proceed with the NIA as per the suggested assessment criteria set out within our letter, and will ensure that the potential cumulative effects are sufficiently considered within our assessment, as per your request.

Kind regards,

Ewan

Sent from [Outlook for iOS](#)



**Ewan Watson**

Principal Consultant

+44 1414283182

[ewan.watson@tneigroup.com](mailto:ewan.watson@tneigroup.com)

[www.tneigroup.com](http://www.tneigroup.com)

---

**From:** [REDACTED]  
**Sent:** Friday, August 9, 2024 8:55:28 AM  
**To:** Ewan Watson <[ewan.watson@tneigroup.com](mailto:ewan.watson@tneigroup.com)>  
**Subject:** RE: Rigifa BESS Development - Noise Impact Assessment

Good afternoon,

Further to the NIA submitted last week I have now had a chance to read through and there is nothing that stands out of concern.

I did think the background level was quite high considering the location but as you have shown historic and current measurements do not show much variation, it can be accepted.

I am satisfied with the suggested approach and would be keen to see the outcome of the accumulative effect from the other nearby sites. This is the main concern for the area being a rise in background or a creeping background effect with any new developments. There is a need to ensure that developers are not examining any monitoring in isolation.

Any further questions please do not hesitate to get in touch.



Regards

[REDACTED]

---

**From:** [REDACTED]  
**Sent:** Friday, August 2, 2024 10:37 AM  
**To:** [REDACTED]  
**Cc:** [REDACTED]  
**Subject:** RE: Rigifa BESS Development - Noise Impact Assessment

**CAUTION:** This email was sent from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Hi [REDACTED]

Hope you are well, and sorry for the delayed response on this.

TNEI are now in a position to progress the NIA report for the proposed Rigifa BESS development, and further to the below would like to provide you with an update in terms of the progress of the assessment (baseline survey etc.) and also our proposed assessment methodology.

The letter attached (16369-003-R1) summarises all the above. Please can you look to review the attached and provide feedback, confirming whether you are satisfied with our suggested assessment approach?

As mentioned in the letter, if you feel a Teams meeting would be usefully to discuss this further, please indicate this and we can look to get something organised.

Kind regards,

Ewan



**Ewan Watson**

Principal Consultant

+44 1414283182

ewan.watson@tneigroup.com

www.tneigroup.com

---

**From:** [REDACTED]  
**Sent:** Tuesday, February 13, 2024 3:12 PM  
**To:** [REDACTED]  
**Subject:** FW: Rigifa BESS Development - Noise Impact Assessment

Good afternoon,

Further to you email below, [REDACTED] has forwarded to me as I am based in the Caithness area and mor appropriate for me to comment.

There are no comments regarding the methodology and I am satisfied with your proposals. It is likely that the background level observed would be below 30dB and a main concern in the area is that of creeping background.

We can discuss further as you state once data has been collated and a background level established.

Regards

[REDACTED]

---

**From:** [REDACTED]  
**Sent:** Thursday, February 8, 2024 11:57 AM  
**To:** [REDACTED]  
**Subject:** FW: Rigifa BESS Development - Noise Impact Assessment

Hi [REDACTED] are you ok to deal with this?

Regards,

[REDACTED]

Environmental Health Officer  
Highland Council, 38 Harbour Road, Inverness, IV1 1UF  
Telephone: [REDACTED]

---

**From:** [REDACTED]  
**Sent:** Thursday, February 8, 2024 11:50 AM  
**To:** [REDACTED]  
**Cc:** [REDACTED]  
[REDACTED]  
**Subject:** Rigifa BESS Development - Noise Impact Assessment

**CAUTION:** This email was sent from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Good Morning [REDACTED]

TNEI have been commissioned to undertake a Noise Impact Assessment in support of the proposed Rigifa Battery Energy Storage System (BESS) development, near to Rigifa, Caithness.

Please find attached a letter delineating our proposed NIA methodology and chosen baseline noise survey locations. I would invite feedback regarding the attached and am happy to address any queries you may have regarding the proposed methodology.

Kind regards,

[REDACTED]



Tel: +44(0)141 4283182

Email: [REDACTED]

Address: TNEI, 7th Floor, 80 St Vincent Street, Glasgow, G2 5UB

*This message, including any attachments, may contain confidential and privileged information for the sole use of the intended recipient(s). Review, use, distribution or disclosure by others is strictly prohibited. If you are not the intended recipient, or authorised to receive information on behalf of the recipient, please contact the sender by reply email, and delete all copies of this message. While we have taken reasonable precautions to ensure that this message and any attachments are free from viruses, we cannot guarantee that they are virus free and accept no liability for any damage caused by this message or any attachments. Messages sent or received through our networks may be monitored to ensure compliance with the law, regulation and/or our policies.*

*Registered in England & Wales No. 03891836*

*Registered Address: TNEI Services Ltd, Bainbridge House, 86-90 London Road, Manchester M1 2PW*


Unless related to the business of The Highland Council, the views or opinions expressed within this e-mail are those of the sender and do not necessarily reflect those of The Highland Council, or associated bodies, nor does this e-mail form part of any contract unless so stated.

Mura h-eil na beachdan a tha air an cur an cèill sa phost-d seo a' buntainn ri gnothachas Chomhairle na Gàidhealtachd, 's ann leis an neach fhèin a chuir air falbh e a tha iad, is chan eil iad an-còmhnaidh a' riochdachadh beachdan na Comhairle, no buidhnean buntainneach, agus chan eil am post-d seo na phàirt de chunntadh sam bith mura h-eil sin air innse.

## Appendix D – Baseline Survey Data


---

## 16369 - Rigifa BESS - Measured Sound Levels:






## 16369 - Rigifa BESS - Measured Sound Levels:




## 16369 - Rigifa BESS - Measured Sound Levels:

### Statistical Analysis - NML01




### Statistical Analysis - NML01




## 16369 - Rigifa BESS - Measured Sound Levels:

### Statistical Analysis - NML02



### Statistical Analysis - NML02





## 16369 - Rigifa BESS - Measured Sound Levels:

### Relevant Statistics

#### NML01

		COUNT	MEAN	MEDIAN	RANGE
DAYTIME	LA90 (15 MINS)	209	48	49	44 - 52
	LAEQ (15 MINS)	209	50	50	45 - 63
NIGHT-TIME	LA90 (15 MINS)	130	48	49	43 - 51
	LAEQ (15 MINS)	130	50	50	45 - 52

#### NML02

		COUNT	MEAN	MEDIAN	RANGE
DAYTIME	LA90 (15 MINS)	439	35	35	20 - 52
	LAEQ (15 MINS)	439	41	42	21 - 64
NIGHT-TIME	LA90 (15 MINS)	271	37	37	20 - 53
	LAEQ (15 MINS)	271	41	41	22 - 59



**Document Name:** Noise Monitoring Field Data Sheet  
**Document Reference:** FDS NOISE - 001 V1.3  
**Document Date:** 27/08/2019

Page 1 of 2

Project Nb.& Name	16369 – Rigifa BESS
Client	Field

#### MONITORING LOCATION DETAILS

NML Nb. and Name	NML01
NML Contact Details (Name, address, phone nb..)	
Description/Reason for exact location and Grid Coordinates	Within landowner's field, adjacent to residential property at Phillip's Mains. X: 329842 Y: 972029

#### MONITORING EQUIPMENT DETAILS

	TNEI Id Nb.	Model	Serial Number	Last Cal.
Sound Level Meter	SLM 038	CR171B	G078532	26/10/2023
Pre Amplifier				
Microphone				
Calibrator				

#### MONITORING EQUIPMENT SETTINGS AT START (TO BE CHECKED AT EACH SITE VISITS)

	Setting	Comment
Index (Leq,L90..)	Leq, L90	
Network (A,B,Z)	A	
Time Interval (10min,10s..)	15 minutes	
Time Weighting (Fast/Slow)	Fast	
Measurement Range (20-110 ..)	20-110	
Audio (No ,Yes 16Khz/16bit ...)	No	
Other (GMT/BST)	GMT	
Resident Comments Sheet	N/A	
Resident consent to use photographs	N/A	

### SITE VISIT HISTORY (VISITS 1 TO 4)

Visit Nb	Surveyor Initials	File Name (on SLM)	Start Date&Time (on watch)	End Date&Time (on watch)	Calibration at Start	Calibration at End	File Name	Index & Network (LAeq, LA90...)	Time Interval (10min, 10s...)	Time Weighting (Fast ...)	Range (20-110 ...)	Batteries	Photographs (Kit+ SLM)	Write Notes on sound audible...	Snow/River Present?
1	WC	-	08/02/2024 16:30	15/02/2024 14:34	93.6	93.7									
2															
3															
4															

Visit Nb	NOTES / SITE OBSERVATIONS / Sounds Audible During Each Visits
1	<p><b><u>Installation</u></b></p> <ul style="list-style-type: none"> <li>- Some snow on ground,</li> <li>- 2/3 oktas, cold, mild to moderate breeze.</li> <li>- Quiet soundscape, wind induced noise is dominant stream close by audible but very windy during installation.</li> </ul>
	<p><b><u>Decommissioning</u></b></p> <ul style="list-style-type: none"> <li>- Bright clear day. 1/2 Oktas, moderate to strong wind.</li> <li>- Stream audible near NML, resident pet dogs barking, occasional bird call (geese overhead)</li> </ul>



**Document Name:** Noise Monitoring Field Data Sheet  
**Document Reference:** FDS NOISE - 001 V1.3  
**Document Date:** 27/08/2019

Page 1 of 2

Project Nb.& Name	16369 – Rigifa BESS
Client	Field

#### MONITORING LOCATION DETAILS

NML Nb. and Name	NML02
NML Contact Details (Name, address, phone nb..)	
Description/Reason for exact location and Grid Coordinates	Located within landowner's field to the southwest of the Residential property at Rigifa. X: 330348 Y: 972559

#### MONITORING EQUIPMENT DETAILS

	TNEI Id Nb.	Model	Serial Number	Last Cal.
Sound Level Meter	SLM 043	CR171B	G056468	27/06/2023
Pre Amplifier				
Microphone				
Calibrator				

#### MONITORING EQUIPMENT SETTINGS AT START (TO BE CHECKED AT EACH SITE VISITS)

	Setting	Comment
Index (Leq, L90..)	Leq, L90	
Network (A,B,Z)	A	
Time Interval (10min,10s..)	15 minutes	
Time Weighting (Fast/Slow)	Fast	
Measurement Range (20-110 ..)	20-110	
Audio (No ,Yes 16Khz/16bit ...)	No	
Other (GMT/BST)	GMT	
Resident Comments Sheet	N/A	
Resident consent to use photographs	N/A	

### SITE VISIT HISTORY (VISITS 1 TO 4)

Visit Nb	Surveyor Initials	File Name (on SLM)	Start Date&Time (on watch)	End Date&Time (on watch)	Calibration at Start	Calibration at End	File Name	Index & Network (LAeq, LA90...)	Time Interval (10min, 10s...)	Time Weighting (Fast ...)	Range (20-110 ...)	Batteries	Photographs (Kit+ SLM)	Write Notes on sound audible...	Snow/River Present?
1	WC	-	08/02/2024 17:45	15/02/2024 14:15	93.7	93.6									
2															
3															
4															


Visit Nb	NOTES / SITE OBSERVATIONS / Sounds Audible During Each Visits
1	<p><b><u>Installation</u></b></p> <ul style="list-style-type: none"> <li>- Some snow on ground, 2/3 oktas, cold. Mild to moderate breeze.</li> <li>- Quiet, noise induced foliage rustle is dominant.</li> </ul>
	<p><b><u>Decommissioning</u></b></p> <ul style="list-style-type: none"> <li>- Bright clear day, 1/2 oktas, Moderate to strong breeze, snow has melted.</li> <li>- Noise induced wind noise and foliage rustle is dominating the soundscape</li> </ul>

# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **26 October 2023**

CERTIFICATE NUMBER **201431**




**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 1

Approved signatory

R.Thomas

Electronically signed:



## Outdoor Kit Calibration Information

### Instrument information

Manufacturer: Cirrus Research plc

Model: CK:675

Preamp Model MK:172

Microphone Serial Number 2026

Primary Calibration Certificate Number 201431

### Summary

Date of calibration: 25 October 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.

This information is in addition to the primary calibration certificate for the sound level meter. The calibration certificate number is shown above and should be used in conjunction with this additional information.

The sound level meter detailed above has been calibrated to the published test and calibration data as detailed in the instrument handbook, using the techniques recommended in the standards to which the instrument has been designed.

All calibration procedures were carried out by substituting the microphone capsule with a suitable electrical signal, apart from the final acoustic calibration.

The microphone capsule was calibrated using an electrostatic calibration system to produce the frequency response and a reference acoustic source for the final sensitivity testing.

In addition to the calibration of the complete sound level meter in its standard configuration, (instrument, MV:200 series preamplifier and microphone capsule), the sound level meter and microphone capsule were tested with the MK:172 preamplifier in place of the MV:200 series.

**The sound level meter, G078532, has been tested with Outdoor Microphone/Preamplifier Type MK:172 Serial Number 2026 and conforms to the requirements of the standards stated in the instrument user manual.**

This certificate provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.



# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **26 October 2023**

CERTIFICATE NUMBER **201431**




**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Sound Level Meter : IEC 61672-3:2013

### Instrument information

Manufacturer: Cirrus Research plc

Notes:

Model: CR:171B

Serial number: G078532

Class: 1

Firmware version: 3.2.3254

### Test summary

Date of calibration: 25 October 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.

Periodic tests were performed in accordance with procedures from IEC 61672-3:2013.

**The sound level meter submitted for testing successfully completed the class 1 periodic tests of IEC 61672-3:2013, for the environmental conditions under which the tests were performed.**

However, no general statement or conclusion can be made about conformance of the sound level meter to the full specifications of IEC 61672-1:2013 because (a) evidence was not publicly available, from an independent testing organisation responsible for pattern approvals, to determine that the model of sound level meter fully conformed to the class 1 specifications in IEC 61672-1:2013 or correction data for acoustical test of frequency weighting were not provided in the Instruction Manual and (b) because the periodic tests of IEC 61672-3:2013 cover only a limited subset of the specifications in IEC 61672-1:2013.


### Notes

This certificate provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.

# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **26 October 2023** CERTIFICATE NUMBER **201432**



**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Octave-band filter : IEC 61260:1995

### Instrument information

Manufacturer: Cirrus Research plc  
Model: CR:171B  
Serial number: G078532  
Class: 1  
Firmware version: 3.2.3254

Notes:

### Test summary

Date of calibration: 25 October 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.  
Periodic tests were performed in accordance with procedures from IEC 61260:1995.

The filter submitted for testing successfully completed the Relative Attenuation test of IEC 61260 for the environmental conditions under which the test was performed.


### Notes

It provides traceability of measurement to the SI system of units and/or to units of measurement realised at a recognised national metrology institute. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.

# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **26 October 2023** CERTIFICATE NUMBER **201430**




**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Third-octave-band filter : IEC 61260:1995

### Instrument information

Manufacturer: Cirrus Research plc  
Model: CR:171B  
Serial number: G078532  
Class: 1  
Firmware version: 3.2.3254

Notes:

### Test summary

Date of calibration: 25 October 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.  
Periodic tests were performed in accordance with procedures from IEC 61260:1995.

The filter submitted for testing successfully completed the Relative Attenuation test of IEC 61260 for the environmental conditions under which the test was performed.

### Notes

It provides traceability of measurement to the SI system of units and/or to units of measurement realised at a recognised national metrology institute. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.



# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **11 October 2023** CERTIFICATE NUMBER **201433**




**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Test engineer:

D.Swalwell

Electronically signed:



## Microphone

### Microphone capsule

Manufacturer: Cirrus Research plc

Model: MK:224

Serial Number: 211155D

### Calibration procedure

Date of calibration: 11 October 2023

Open circuit: 43.9 mV/Pa

Sensitivity at 1 kHz: -27.2 dB rel 1 V/Pa

The microphone capsule detailed above has been calibrated to the published data as described in the operating manual of the associated sound level meter (where applicable).

The frequency response was measured using an electrostatic actuator in accordance with BS EN 61094-6:2005 with the free-field response derived via standard correction data traceable to a National Measurement Institute.

The absolute sensitivity at 1 kHz was measured using an acoustic calibrator conforming to IEC 60942:2003 Class 1.

### Environmental conditions

Pressure: 99.94 kPa

Temperature: 23.4 °C

Humidity: 54.7 %

# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **26 October 2023**

CERTIFICATE NUMBER **201434**



**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Sound Calibrator : IEC 60942:2003

### Instrument information

**Manufacturer:** Cirrus Research plc

**Notes:**

**Model:** CR:515

**Serial number:** 78219

**Class:** 1

### Test summary

**Date of calibration:** 25 October 2023

The sound calibrator detailed above has been calibrated to the published data as described in the operating manual and in the half-inch configuration. The procedures and techniques used are as described in IEC60942\_2003 Annex B – Periodic Tests and three determinations of the sound pressure level, frequency and total distortion were made.

The sound pressure level was measured using a WS2F condenser microphone type MK:224 manufactured by Cirrus Research plc.

The results have been corrected to the reference pressure of 101.33 kPa using the manufacturer's data.

As public evidence was available, from a testing organisation responsible for approving the results of pattern evaluation tests, to demonstrate that the model of sound calibrator fully conformed to the requirements for pattern evaluation described in Annex A of IEC 60942:2003, the sound calibrator tested is considered to conform to all the Class 1 requirements of IEC 60942:2003.

The manufacturer's product information indicates that this model of sound calibrator has been formally pattern approved to IEC60942\_2003 Annex A to Class 1. This has been confirmed by Laboratoire National d'Essais (LNE), Physikalisch-Technische Bundesanstalt (PTB) and APPLUS (APPLUS).

**Notes:**




# CERTIFICATE OF CALIBRATION

ISSUED BY Cirrus Research

DATE OF ISSUE 28 June 2023

CERTIFICATE NUMBER 194370



Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Sound Level Meter : IEC 61672-3:2013

### Instrument information

Manufacturer: Cirrus Research plc

Notes:

Model: CR:171B

Serial number: G056468

Class: 1

Firmware version: 3.2.3254

### Test summary

Date of calibration: 27 June 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.

Periodic tests were performed in accordance with procedures from IEC 61672-3:2013.

**The sound level meter submitted for testing successfully completed the class 1 periodic tests of IEC 61672-3:2013, for the environmental conditions under which the tests were performed.**

However, no general statement or conclusion can be made about conformance of the sound level meter to the full specifications of IEC 61672-1:2013 because (a) evidence was not publicly available, from an independent testing organisation responsible for pattern approvals, to determine that the model of sound level meter fully conformed to the class 1 specifications in IEC 61672-1:2013 or correction data for acoustical test of frequency weighting were not provided in the Instruction Manual and (b) because the periodic tests of IEC 61672-3:2013 cover only a limited subset of the specifications in IEC 61672-1:2013.

### Notes

This certificate provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.



# CERTIFICATE OF CALIBRATION

Certificate Number:  
**194370**

Page 2 of 2

## Environmental conditions

The following conditions were recorded at the time of the test:

<b>Before</b>	Pressure: 101.24 kPa	Temperature: 20.8 °C	Humidity: 41.4 %
<b>After</b>	Pressure: 101.21 kPa	Temperature: 20.8 °C	Humidity: 40.9 %

## Test equipment

Equipment	Manufacturer	Model	Serial number
Signal Generator	KEYSIGHT	33511B	MY58001553
Attenuator	Cirrus Research	ZE:952	52200
Environmental Monitor	Comet	T7510	16966334

## Additional instrument information

Instruction manual:

Reference level range: Single range

Pattern approval: No

Source of pattern approval: -

### Preamplifier

Model: MV:200F

Serial number: 0418F

### Microphone

Model: MK:224

Serial number: 204031A

## Test results summary


Test	Result
Toneburst response	Complies
Electrical noise-floor	Complies
Linearity	Complies
Electrical Frequency weightings	Complies
Frequency and time weightings at 1 kHz	Complies
C-weighted peak	Complies
Overload indication	Complies
High level stability	Complies
Long-term stability	Complies
Acoustic Frequency weightings	Complies

# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **28 June 2023**

CERTIFICATE NUMBER **194369**




**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Octave-band filter : IEC 61260:1995

### Instrument information

Manufacturer: Cirrus Research plc  
Model: CR:171B  
Serial number: G056468  
Class: 1  
Firmware version: 3.2.3254

Notes:

### Test summary

Date of calibration: 27 June 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.

Periodic tests were performed in accordance with procedures from IEC 61260:1995.

The filter submitted for testing successfully completed the Relative Attenuation test of IEC 61260 for the environmental conditions under which the test was performed.

### Notes

It provides traceability of measurement to the SI system of units and/or to units of measurement realised at a recognised national metrology institute. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.

# CERTIFICATE OF CALIBRATION

Certificate Number:

194369

Page 2 of 2

## Environmental conditions

The following conditions were recorded at the time of the test:

**Before**    Pressure: 101.24 kPa    Temperature: 20.8 °C    Humidity: 41.4 %

**After**    Pressure: 101.21 kPa    Temperature: 20.8 °C    Humidity: 40.9 %

## Test equipment

Equipment	Manufacturer	Model	Serial number
Signal Generator	KEYSIGHT	33511B	MY58001553
Attenuator	Cirrus Research	ZE:952	52200
Environmental Monitor	Comet	T7510	16966334

## Filters information

Filter class: 1

Filter base: 2

Reference attenuation: 0.0 dB

## Additional instrument information

Instruction manual:

Pattern approval: No

Source of pattern approval: -

Reference level range: Single range

## Laboratory uncertainties

Requirement	Value (dB)
Relative Attenuation High	0.41
Relative Attenuation Mid	0.18
Relative Attenuation Low	0.12

# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **28 June 2023**

CERTIFICATE NUMBER **194371**




**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Third-octave-band filter : IEC 61260:1995

### Instrument information

Manufacturer: Cirrus Research plc  
Model: CR:171B  
Serial number: G056468  
Class: 1  
Firmware version: 3.2.3254

Notes:

### Test summary

Date of calibration: 27 June 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.

Periodic tests were performed in accordance with procedures from IEC 61260:1995.

The filter submitted for testing successfully completed the Relative Attenuation test of IEC 61260 for the environmental conditions under which the test was performed.

### Notes

It provides traceability of measurement to the SI system of units and/or to units of measurement realised at a recognised national metrology institute. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.



# CERTIFICATE OF CALIBRATION

Certificate Number:  
**194371**

Page 2 of 2

## Environmental conditions

The following conditions were recorded at the time of the test:

**Before**    Pressure: 101.24 kPa    Temperature: 20.8 °C    Humidity: 41.4 %  
**After**     Pressure: 101.21 kPa    Temperature: 20.8 °C    Humidity: 40.9 %

## Test equipment

Equipment	Manufacturer	Model	Serial number
Signal Generator	KEYSIGHT	33511B	MY58001553
Attenuator	Cirrus Research	ZE:952	52200
Environmental Monitor	Comet	T7510	16966334

## Filters information

Filter class: 1  
Filter base: 2  
Reference attenuation: 0.0 dB

## Additional instrument information

Instruction manual:  
Pattern approval: No  
Source of pattern approval: -  
Reference level range: Single range

## Laboratory uncertainties


Requirement	Value (dB)
Relative Attenuation High	0.41
Relative Attenuation Mid	0.18
Relative Attenuation Low	0.12

# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **28 June 2023**

CERTIFICATE NUMBER **194370**



**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 1

Approved signatory

R.Thomas

Electronically signed:



## Outdoor Kit Calibration Information

### Instrument information

Manufacturer: Cirrus Research plc  
Model: CK:675  
Preamp Model: MK:172  
Microphone Serial Number: 2348  
Primary Calibration Certificate Number: 194370

### Summary

Date of calibration: 27 June 2023

The calibration was performed respecting the requirements of ISO/IEC 17025:2017.

This information is in addition to the primary calibration certificate for the sound level meter. The calibration certificate number is shown above and should be used in conjunction with this additional information.

The sound level meter detailed above has been calibrated to the published test and calibration data as detailed in the instrument handbook, using the techniques recommended in the standards to which the instrument has been designed.

All calibration procedures were carried out by substituting the microphone capsule with a suitable electrical signal, apart from the final acoustic calibration.

The microphone capsule was calibrated using an electrostatic calibration system to produce the frequency response and a reference acoustic source for the final sensitivity testing.

In addition to the calibration of the complete sound level meter in its standard configuration, (instrument, MV:200 series preamplifier and microphone capsule), the sound level meter and microphone capsule were tested with the MK:172 preamplifier in place of the MV:200 series.

**The sound level meter, G056468, has been tested with Outdoor Microphone/Preamplifier Type MK:172 Serial Number 2348 and conforms to the requirements of the standards stated in the instrument user manual.**


This certificate provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.



# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **22 June 2023** CERTIFICATE NUMBER **194372**




**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Test engineer:

D.Swalwell

Electronically signed:



## Microphone

### Microphone capsule

Manufacturer: Cirrus Research plc

Model: MK:224

Serial Number: 204031A

### Calibration procedure

Date of calibration: 22 June 2023

Open circuit: 43.9 mV/Pa

Sensitivity at 1 kHz: -27.2 dB rel 1 V/Pa

The microphone capsule detailed above has been calibrated to the published data as described in the operating manual of the associated sound level meter (where applicable).

The frequency response was measured using an electrostatic actuator in accordance with BS EN 61094-6:2005 with the free-field response derived via standard correction data traceable to a National Measurement Institute.

The absolute sensitivity at 1 kHz was measured using an acoustic calibrator conforming to IEC 60942:2003 Class 1.

### Environmental conditions

Pressure: 101.20 kPa

Temperature: 21.0 °C

Humidity: 55.0 %

# CERTIFICATE OF CALIBRATION


Certificate Number:  
**194372**

Page 2 of 2

## Free-Field Frequency Response : Tabular

Frequency (Hz)	Free-Field Sensitivity (dB rel 1 kHz)	Actuator Response (dB)
<b>63</b>	<b>0.02</b>	<b>-0.17</b>
80	0.03	-0.06
100	-0.01	0.00
<b>125</b>	<b>0.03</b>	<b>0.04</b>
160	0.02	0.05
200	0.00	0.04
<b>250</b>	<b>0.01</b>	<b>0.06</b>
315	0.02	0.05
400	0.01	0.05
<b>500</b>	<b>0.02</b>	<b>0.05</b>
630	0.02	0.04
800	0.00	0.02
<b>1 000</b>	<b>0.00</b>	<b>0.00</b>
1 250	-0.01	-0.05
1 600	0.00	-0.12
<b>2 000</b>	<b>0.00</b>	<b>-0.21</b>
2 500	-0.01	-0.35
3 150	-0.03	-0.59
<b>4 000</b>	<b>-0.07</b>	<b>-0.99</b>
5 000	-0.14	-1.52
6 300	-0.21	-2.33
<b>8 000</b>	<b>-0.38</b>	<b>-3.58</b>
10 000	-0.77	-5.46
12 500	-0.90	-7.35
<b>16 000</b>	<b>-1.81</b>	<b>-9.64</b>
20 000	-4.71	-13.75

## Free-Field Frequency Response : Graphical




# CERTIFICATE OF CALIBRATION

ISSUED BY **Cirrus Research**

DATE OF ISSUE **28 June 2023**

CERTIFICATE NUMBER **194373**



**Cirrus Research  
Acoustic House  
Bridlington Road  
Hunmanby  
North Yorkshire  
YO14 0PH  
United Kingdom**

Page 1 of 2

Approved signatory

R.Thomas

Electronically signed:



## Sound Calibrator : IEC 60942:2003

### Instrument information

**Manufacturer:** Cirrus Research plc

**Notes:**

**Model:** CR:511E

**Serial number:** 038873

**Class:** 1

### Test summary

**Date of calibration:** 27 June 2023

The sound calibrator detailed above has been calibrated to the published data as described in the operating manual and in the half-inch configuration. The procedures and techniques used are as described in IEC60942\_2003 Annex B – Periodic Tests and three determinations of the sound pressure level, frequency and total distortion were made.

The sound pressure level was measured using a WS2F condenser microphone type MK:224 manufactured by Cirrus Research plc.

The results have been corrected to the reference pressure of 101.33 kPa using the manufacturer's data.

The sound calibrator has been shown to conform to the Class 1 requirements for periodic testing, described in Annex B of IEC 60942:2003 for the sound pressure level(s) and frequency(ies) stated, for the environmental conditions under which the tests were performed.

However, as public evidence was not available, from a testing organisation responsible for pattern approval, to demonstrate that the model of sound calibrator conformed to the requirements for pattern evaluation described in Annex A of IEC 60942:2003, no general statement or conclusion can be made about conformance of the sound calibrator to the requirements of IEC 60942:2003.

**Notes:**

This certificate provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. The results within this certificate relate only to the items calibrated. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k=2$ , providing a coverage probability of approximately 95%.



# CERTIFICATE OF CALIBRATION

Certificate Number:  
**194373**

Page 2 of 2

## Environmental conditions

The following conditions were recorded at the time of the test:

Pressure: 100.94 kPa

Temperature: 22.8 °C

Humidity: 49.1 %

## Test equipment

Equipment	Manufacturer	Model	Serial number
Distortion Meter	Keithley	2015	0994818
Acoustic Calibrator	Bruel and Kjaer	4231	2610257
Environmental Monitor	Comet	T7510	21962628

## Results

	Expected	Sample 1	Sample 2	Sample 3	Average	Deviation	Tolerance	Uncertainty
Level (dB)	94.00	94.06	94.05	94.08	<b>94.06</b>	0.06	±0.40	0.11 dB
Distortion (%)	< 3.00	0.36	0.36	0.34	<b>0.35</b>	0.35	+3.00	0.13 %
Frequency (Hz)	1000.0	993.9	993.9	993.9	<b>993.9</b>	-6.1	±10.0	0.1 Hz
Level (dB)	104.00	104.01	104.01	104.00	<b>104.01</b>	0.01	±0.40	0.11 dB
Distortion (%)	< 3.00	0.31	0.31	0.30	<b>0.31</b>	0.31	+3.00	0.13 %
Frequency (Hz)	1000.0	993.9	993.9	993.9	<b>993.9</b>	-6.1	±10.0	0.1 Hz

The measured quantities or deviations (as applicable), extended by the expanded combined uncertainty of measurement, must not exceed the corresponding tolerance.

End of results

## Appendix E – Noise Modelling Data

---

# HV Grid Transformer Data



## TEST REPORT

Report No.:  
2021/0141/031  
Page 22 of 68

### Sound Level

Serial No. : 1ZPL001134582

#### Combination of sound level measurements

Rated voltage	Applied voltage	Rated current	Applied current	Tap position	Fans in operation	Pumps in operation
[kV]	[kV]	[A]	[A]			
100	33	100	262.43		8	

Rated voltage	Applied voltage	Rated current	Applied current	Tap position	Fans in operation	Pumps in operation
[kV]	[kV]	[A]	[A]			

Frequency	Measurement 1 Sound Power Level	Measurement 4 Sound Power Level	Combined Sound Power Level
[Hz]	[dB(A)]	[dB(A)]	[dB(A)]

Frequency	Combined Sound Power Level
[Hz]	[dB(A)]

Total Sound Level		76.9	87.8	88.2
-------------------	--	------	------	------

Total Sound Level				
-------------------	--	--	--	--

Octave Band	63	39.6	64.4	64.4
	125	59.5	79.6	79.6
	250	76.1	81.2	82.3
	500	67.3	82.6	82.7
	1000	56.3	81.7	81.7
	2000	51.6	75.4	75.4
	4000	54.1	71.3	71.4
	8000	57.4	64.2	65.0

Octave Band	63			
	125			
	250			
	500			
	1000			
	2000			
	4000			
	8000			

1/3 Octave Band	50	36.1	63.8	63.8
	63	37.0	47.4	47.8
	80	0.0	55.1	55.1
	100	58.4	71.9	72.1
	125	47.5	68.5	68.6
	160	51.3	78.4	78.4
	200	63.1	73.7	74.1
	250	60.9	76.4	76.5
	315	75.8	78.0	80.1
	400	61.2	77.0	77.1
	500	63.7	76.9	77.1
	630	62.5	79.2	79.3
	800	53.7	78.6	78.6
	1000	51.4	76.7	76.7
	1250	47.1	74.5	74.5
	1600	47.0	72.4	72.4
	2000	46.7	70.2	70.2
	2500	46.9	68.5	68.5
	3150	48.4	67.5	67.6
	4000	49.6	66.9	67.0
	5000	49.9	64.8	64.9
	6300	51.2	61.5	61.9
	8000	52.9	58.8	59.8
	10000	53.6	56.4	58.2

1/3 Octave Band	50			
	63			
	80			
	100			
	125			
	160			
	200			
	250			
	315			
	400			
	500			
	630			
	800			
	1000			
	1250			
	1600			
	2000			
	2500			
	3150			
	4000			
	5000			
	6300			
	8000			
	10000			

Issue Date  
29/09/2021

Test Engineer  
Kamil Maliński


Test Department  
Test Field



## Appendix F – Figures

---





LEGEND

- Red Line Boundary
- Noise Sensitive Receptors (NSRs)
- Noise Monitoring Locations (NMLs)
  - NML01
  - NML02

Note: The measured noise levels at NML02 have been used to represent all NSRs and NML01 measured levels were not used. The main reason is that NML01 levels found to be high and unrepresentative because of water course noise.

1	25/09/2024	SECOND ISSUE	ST	EW
0	28/08/2024	FIRST ISSUE	FU	MC
Rev.	Date	Amendment Details	Drawn	Approved




This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.



Client	FIELD		
Drawing Status:	FOR INFORMATION		
Project Title:	RIGIFA BESS		
Drawing Title:	FIGURE 01 - NOISE STUDY AREA		
Scale:	1:10,000	Original Size:	A3
		Spatial Reference:	British National Grid
Drawing Number:	16369-005		





**LEGEND**

Red Line Boundary

Noise Assessment Locations

Modelled Noise Sources

Modelled Buildings

Site Layout

**Predicted Noise Levels (dBA)**

10 - 15

15 - 20

20 - 25

25 - 30

30 - 35

35 - 40

40 - 45

45 - 50

50 - 55

55 - 60

60 - 65

65 - 70

Noise contours modelled in accordance with ISO 9613 Part 2 at a height of 4 m and displayed on a 10 m by 10 m grid.

All noise sources assumed to be operating concurrently.

All levels shown as dB LAeq(t).

Rev.	Date	Amendment Details	Drawn	Approved
1	25/09/2024	SECOND ISSUE	ST	EW
0	28/08/2024	FIRST ISSUE	FU	MC

HOY Lyness

Burray

St Margaret's Hope

South Ronaldsay

Dunnet Head

Stroma

Duncansby Head

Thurso

Halkirk

Altnabreac Station

Contains OS data © Crown Copyright and database right 2022

This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.

tnei

Client

**FIELD**

Drawing Status:

FOR PLANNING

Project Title:

RIGIFA BESS

Drawing Title:

FIGURE 02 - NOISE CONTOUR PLOT

Scale:

1:7,250

Original Size:

A3

Spatial Reference:

British National Grid

Drawing Number:

16369-006

Contains OS data © Crown copyright and database rights 2024 Ordnance Survey 0100031673

## Appendix G – One-Third Octave Band Predicted Levels (dBZ)

Noise Assessment Location (NAL)	External Predicted Noise Levels, dB(Z)																											
	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
NAL01 – Phillips Mains A	36	34	33	32	28	26	26	21	21	18	17	17	14	13	12	12	-	-	-	-	-	-	-	-	-	-	-	-
NAL02 – Phillips Mains B	36	34	32	31	28	25	25	20	20	17	16	15	12	11	10	11	7	2	-	-	-	-	-	-	-	-	-	-
NAL03 – West Lodge	36	34	32	31	28	26	26	21	21	19	18	17	15	14	13	15	12	7	-	-	-	-	-	-	-	-	-	-
NAL04 – East Lodge	33	31	29	28	26	24	23	18	18	16	15	14	11	11	10	11	8	-	-	-	-	-	-	-	-	-	-	-
NAL05 – Rigifa	32	30	28	27	24	22	21	17	16	14	13	11	9	8	7	9	5	-	-	-	-	-	-	-	-	-	-	-
Where a dash (-) is presented, predicted values were negligibly low (0 dB or below), and as such were not included within the table.																												

## Appendix H – Cumulative Assessment Table

**Table H-1: Cumulative BS 4142 Assessment**

Noise Assessment Location (NAL)				A - Proposed Development Rating Level, dBA by TNEI	B - Mey BESS Rating Level, dBA by third party other than TNEI	C - Gills Bay Substation Rating Level, dBA by third party other than TNEI	D - Hollandmey Renewable Energy Development Rating Level, dBA by third party other than TNEI	Cumulative Rating Level excluding Proposed Development (B+C+D)	Cumulative Rating Level including Proposed Development (A+B+C+D)	Representative Background Sound Level, dBA
Proposed Development	Equivalent Mey BESS	Equivalent Gills Bay Substation	Equivalent Hollandmey Renewable Energy Development							
NAL01 - Phillips Mains A	NSR1	Phillips Mains	Not Named	20	39	20	30†	40	40	35
NAL02 - Phillips Mains B	NSR1	Phillips Mains	Not Named	18	39	20	30†	40	40	35
NAL03 - West Lodge	NSR2	West Lodge	Not Named	21	33	25	30†	35	35	35
NAL04 - East Lodge	NSR4	*N/A	Not Named	18	35	-	30†	36	36	35
NAL05 - Rigifa	*N/A	*N/A	Not Named	15	-	-	30†	30	30	35
* Noise Rating Levels were not predicted (or presented) at these locations within respective NIAs										
† The NIA report for the Hollandmey Renewable Energy development does not present BS 4142 Rating Levels, rather it states that the site will be designed to meet 30 dBA at all nearby receptors. As such, this value has been assumed to inform the cumulative assessment.										



## 9 References

1. **The Scottish Government.** *PAN 1/2011 Planning and Noise*. Scotland : The Crown, 2011.
2. —. *Technical Advice Note (TAN) 'Assessment of Noise'*. Scotland : The Crown, 2011.
3. **British Standards Institute.** *Methods for Rating and Assessing Industrial and Commercial Sound*. UK : BSI, 2014. BS4142:2014 + A1:2019.
4. **The Association of Noise Consultants (ANC).** *BS 4142:2014+A1:2019 - Technical Note*. s.l. : The Association of Noise Consultants (ANC), 2020.
5. **Datakustik GmbH.** CadnaA. 2024.
6. **(ISO), International Organization for Standardization.** *Acoustics – Attenuation of Sound During Propagation Outdoors: Part 2 – General Method of Calculation*. Geneva : (ISO), International Organization for Standardization. ISO 9613-2.
7. **Commission Electrotechnique Internationale (IEC).** *Electroacoustics - Sound level meters - Part 1: Specifications*. Geneva : IEC, 2013. IEC 61672-1:2013.
8. **University of Salford, Manchester.** *Procedure for the assessment of low frequency noise disturbance*. s.l. : DEFRA, 2011.